

Technical Bulletin

May 2026


Dear valued customer,

RE: Taktis EN13 firmware wireless network legacy mode

Changes have been introduced in the EN13 Taktis firmware that affect the EMS wireless Taktis panel networks using the EMS Taktis Radio Network Communicator. To allow the EMS wireless network to work with the EN13 Taktis firmware Kentec have added a Legacy wireless mode to the LE2 configuration options. This legacy mode does not affect the general operation of the Taktis network but does allow the wireless network to function as it did on previous versions of Taktis firmware.

This mode can only be enabled using LE2 software-

Once the site configuration has been downloaded from all network panels using LE2, Select Edit Properties by right clicking the site name-



Tick both Legacy wireless networking options and click save-

Network Site Details

Site Name: Legacy

Master Clock Node: 1 Taktis

Alarm Verification:

Type: None

Seconds: 01

Network Communications: 115200 (dflt)

DIN VDE 0833 – Meldergruppen mode: WARNING: Select only for markets where Meldergruppen mode is used.

Legacy Wireless Networking: WARNING: Selection required for Radio Network Communicator (RNC) Firm ware revision 3.02 or less.

Use Legacy Zone Disablement behaviour

Save Cancel

Upload the configuration to all Network panels.

For additional help please contact ems.technical@kgsolutions.com